

STORM WATER MANAGEMENT BMP
 SCHEDULE OF LONG TERM MAINTENANCE ACTIVITIES
 PROVIDENCE, UT

Activity	Frequency	Notes
Inspection	Annually	It is recommended that the SMP Operation Maintenance Inspection Report, referenced by this Agreement, be used as a guiding document. This annual inspection should be submitted to the City upon completion.
Mowing and maintenance of vegetation	Variable, depending on vegetation and desired aesthetics	Landscaping and vegetation should be cared for throughout the year to ensure that proper sediment removal and infiltration is maintained and the Facilities remain aesthetically appealing.
Remove trash and debris	As needed or following each storm	Trash and debris should be removed regularly to ensure that the Facilities function properly and operate effectively. Trash often collects at inlet and outlet structures.
Inspect and maintain inlet and outlet structures	Annually	The inlet and outlet structures should be inspected for damage and proper operations.
Sediment removal	Variable (5-10 years is typical)	The removal of sediment is necessary if the Facilities begin to lose capacity or effectiveness.